

Reporting past due red or yellow fire sprinkler tag and pre-engineered systems deficiencies for state owned buildings only.

In compliance 69A-46.041(4)(b)- If the building owner or authorized representative has not contracted with the inspecting contractor so that the noncritical deficiencies are corrected within 30 days for a red tag or 90 days for a yellow tag from the date of the inspection, or the inspecting contractor has not received confirmation from the building owner or authorized representative that the corrections have been performed by another licensed contractor, the inspecting contractor must notify the local authority having jurisdiction (AHJ).

In compliance with 633.308(1) A copy of the inspection report shall be provided to the owner at the time of inspection, and, if a pre-engineered system in a state-owned building is found to be in violation of this chapter, the manufacturer's specifications, or the standards of the National Fire Protection Association, a copy shall be forwarded to the state within 30 days from the date of service.

Please send these notifications for state owned buildings to FSR@myfloridacfo.com. Sending non- state-owned building sprinkler reports or pre-engineered system reports to this address will not satisfy the requirements